

# CA75

Date: August 23, 1996

Ref: Ca075-0

Revision: 00

Author:

<b>Cable code</b>	CA75
<b>Description</b>	PLC port to TSI02 Bus Terminal
<b>Type of Communication</b>	RS-485
<b>Panel Connector</b>	D-sub type 15S
<b>TSI02 Connector</b>	D-sub type 15P
<b>Notes</b>	This cable is intended for use with the UniNET network. The maximum length is 2 meters.

table 1. Cable description




figure 1. Cable diagram